



台灣檢驗科技股份有限公司
SGS Taiwan Ltd.

高雄市三民區中華二路 266 號
電話：(07)3230920
傳真：(07)3215489

試驗報告

報告號碼：KV-2002-2-2201
頁數：1 OF 1
日期：91年 04月 23日

委託者：國開營造股份有限公司
申請廠商：久鋒國際企業股份有限公司, 泰聯企業有限公司
工程名稱：高雄臨時車站工程
貨品：矽利康
採樣者：久鋒國際企業股份有限公司, 貫聯興業有限公司(胡昱嘉)
送樣日期：91年 02月 22日


試驗結果

試驗項目	試驗方法	試驗結果	規範要求
耐久性(9030)	CNS 8903 & CNS 8904	試體無接著不良 及無龜裂現象	試體無接著不良 及無龜裂現象

----- ○ ○ ○ -----

除非獲得本實驗室書面同意，此份報告不能摘錄複製，但全部複製除外。

影本與正本相符


報告簽署人

本試驗僅對送驗樣品負責

This report is issued by the Company under its General Conditions for Inspection and Testing Services, printed overleaf. The issuance of this Report does not exonerate buyers or sellers from exercising all their rights and discharging all their liabilities under the Contract of Sale. Stipulations to the contrary are not binding on the Company. The Company's responsibility under this report is limited to proven negligence and will in no case be more than ten times the amount of the fees or commission. Except by special arrangement, samples, if drawn, will not be retained by the Company for more than three months.
本證明書為本公司依據背頁之檢驗及測試服務共同條款所製發。本證明書之製發，並不免除買賣雙方依買賣合約所得行使之權利及所應履行之義務。違反本證明書之約定並不拘束本公司。本公司製發本證明書之責任僅限於經證明之過失，且責任範圍僅限於收取之費用或報酬金額之十倍。除有特別約定外，本公司對檢驗之樣品之保管，不超過三個月。